

INSTALLATION AND OPERATING INSTRUCTIONS for SB Blast Chiller Models



809-244A Rev. B. 11/19/2025 3779 CHAMPION BLVD, WINSTON-SALEM, NC 27105 Phone: (888) 845-9800 | Fax: (800) 253-5168 | Web: beverage-air.com

SEE BACK COVER FOR WARRANTY REGISTRATION

WELCOME

Thank you for purchasing a Beverage-Air cabinet. This series has passed our strict quality control inspection and meets the high standards set by Beverage-Air Refrigeration! You have made a quality investment that with proper maintenance will give you many years of reliable service!

Please read the following installation and maintenance instructions before installing or using your unit.

Important Information

- PLEASE READ THESE INSTRUCTIONS CAREFULLY BEFORE INSTALLING OR USING, IF RECOMMENDED PROCEDURES ARE NOT FOLLOWED, WARRANTY CLAIMS MAY BE DENIED.
- Your warranty registration information is located within this manual. Please complete the card and submit it to Beverage-Air Refrigeration within TEN days of installation. Failure to properly register equipment may limit or void the warranty.
- Beverage-Air Refrigeration reserves the right to change specifications and product design without notice. Such revisions do not entitle the buyer to corresponding changes, improvements, additions, or replacements for previously purchased equipment.
- THE MANUFACTURER DECLINES LIABLITY FOR NON-DECLARED USE OF THE PRODUCT. THE REPRODUCTION OF THIS MANUAL OR ITS PARTS THEROF, IS PROHIBITED.

CONTENTS

Welcome	2
Product Information	4
Electrical	5
Safety Precautions for Using the Equipment	6
Installation	
Using the Controller	
Maintenance and Cleaning	26
Methods For Cleaning Stainless Steel	28
In Case of Equipment Malfunction	29
Alarm Codes	32
Locating the Serial Plate	34
For the Service Tech = Wiring Diagram	35
Limited Warranty	37

This appliance has been designed with your safety in mind. It has many features to keep you from being harmed. However, safe operation and maintenance are your responsibilities.



Use: When using this unit, please:

- Move it carefully. If on casters be sure the casters do NOT run over the power cord.
- Lock the casters when in use.
- **Seek help.** This machine is heavy! Be sure to move with enough help to avoid tipping or dropping the cabinet.



Maintenance

Do NOT:

- Clean a frozen evaporator with a sharp object
- · Clean a dirty condenser with a sharp object.
- Store gasoline, kerosene or any other flammable material near the cabinet.

- Prevent children from playing in or on the cabinet. Persons unable to use this product must be prevented access.
- Follow all instructions. There are many safety labels and directions on the unit. Heed them.
- Watch your fingers. There may be pinch points near the door hinges.

Do ALWAYS

- Use a Beverage-Air recommended technician certified to repair R290 equipment.
- Use ONLY Beverage-Air factory service parts. Use of non OEM parts can be dangerous because of the design changes needed to safely use R290.
- Wear gloves to perform maintenance on the motor components or the evaporating unit inside the machine.

Important Information to Add

Record the model number, serial number and the date of installation here for future reference. The model and serial numbers are on the unit's serial number dataplate, which is located on the left inside wall.

Model Number	
Serial Number	
Date of Installation	
Purchased From	





Observe the **Caution** and **Warning** notices. They are indicators of important safety information. Keep this manual for future reference.

PRODUCT INFORMATION

This unit is intended to be used in a commercial application. That includes bars and restaurants.

If installed in a residence some commercial service companies may not be able to service it on site.

The manufacturer has designed and produced this machine with the finest in materials. The manufacturer assumes no liability for units that have been altered in any way. Alterations or part substitutions will void the warranty.

Limitations

The machine is designed for use indoors in a controlled environment. It must be kept dry, not overheated or subjected to excessive cold. May only be connected to a dedicated electrical circuit. Extension cords are not permitted.

Model	Cabinet Dimensions w x d x h (Inches)	Door	Full Load Amps	Refrigerant Charge R-290 (g) / (oz)	Voltage	NEMA Plug
SB-031-RA-HC	24.6 X 27.6 X 23.62	1	3.47	80 / 2.82	115/60/1	5-15P

Height includes legs.

- Blast Chilling Cycle rapidly lowers the temperature of the contents from 149°F to 50°F in 90 minutes
- Shock Freezing Cycle lowers the temperature from 149°F to 0°F in 240 minutes
- ALWAYS REFERENCE YOUR EQUIPMENT DATA PLATE AMPS, REFRIGERANT AND REFRIGERANT CHARGE FOR THE MOST UP TO DATE AND ACCURATE VALUES.

Agency Approvals

These marks appear on the dataplate or serial tag, located in the inside of the left wall. The dataplate also contains the model and serial numbers as well as electrical requirements.







ELECTRICAL

The self-contained models are cord-connected units, and must be connected to their own **dedicated** power supply. Check the dataplate on the machine to confirm the voltage and per the dataplate use the correct fuses or HACR circuit breakers.

Note: Do not connect to GFI / GFCI outlets. Connection to that type of outlet can result in product loss due to unsafe cabinet temperature when GFI device trips from moisture.

Power Cord

This model is equipped with a power cord and 5-15P plug.

If the power cord becomes damaged, it must be replaced with the identical cord.

Follow All National and Local Codes

This Unit Must Be Grounded. Do not use extension cords and do not disable or by-pass ground prong on electrical plug.

Initial Start Up

Plug the power cord into the proper power supply.

The cabinet will soon begin to blow warm air out of the front grille area, and cool air will flow from the inside blower.

Cautions

Care must be taken whenever moving or servicing the unit. The refrigerant is contained in a sealed system, but if released it is flammable.

SAFETY PRECAUTIONS FOR USING THE EQUIPMENT

RECIPIENTS OF THIS MANUAL

This manual provides users of the machine with all the information necessary for its use and routine maintenance. Before each operation, carefully read the instructions and warnings contained in the manual as they provide essential safety indications. The manual is an integral part of the machine and must accompany it throughout its life cycle. In case of transfer of the machine, the manual must be provided to the new owner. In case of loss or damage, request a copy from the Manufacturer, specifying the model of the machine to which it refers (COMPACT-CHILLY blast chiller). This manual refers to the COMPACT-CHILLY blast chiller, an appliance capable of lowering quickly the temperature of the food introduced, whether fresh or cooked.

SYMBOLS USED WITHIN THE MANUAL AND ON THE MACHINE

The following symbols are affixed inside the manual and on the machine that facilitate safe understanding of the steps involved.

	symbol applied on the machine	symbol in the manual						
		DANGER : An imminent risk situation that, if not avoided, causes instantaneous death or serious or permanent damage to health.						
	not present	WARNING : A potential risk situation that, if not avoided, may cause death or serious damage to health.						
		WARNING : A potential risk situation that, if not avoided, could cause minor damage						
	The symbol indicates that the surfaces marked by this symbol could be very hot or very cold and must therefore be touched carefully and using PPE (e.g. gloves)	The symbol indicates that operations marked with this symbol could cause thermal hazards (e.g. scalding or frostbite). The operations must therefore be carried out: - Carefully - Using PPE (e.g. gloves).						
	If present, the symbols are positioned on refrigeration unit and indicate the flammability of the gas.							
	WARNING							
	Do not use means to accelerate the defrosting process or to clean, other than those recommended by the manufacturer.							
	The appliance shall be stored in a room without continuously operating ignition sources (for example: open flames, an operating gas appliance or an operating electric heater).							
	Do not pierce or burn.							
	Be aware that refrigerants may not o	contain an odour.						
4	The symbol indicates that the guards marked with this symbol prevent contact with high-voltage parts.	The symbol indicates that operations marked with this symbol could cause electrical hazards (e.g. electrocution or electric shock). The operations must therefore be carried out:						
	Do not remove or modify the guards marked with this symbol: electrocution hazard	- After disconnecting the power supply to the machine - Carefully - Using PPE (e.g. gloves).						
	not present	The symbol indicates the need to read the manual carefully before installation, use and maintenance of the equipment.						

SAFETY WARNINGS FOR INSTALLATION

FAILURE TO OBSERVE THE FOLLOWING RULES MAY RESULT IN DAMAGE AND INJURY, INCLUDING DEATH, AND MAY CAUSE THE WARRANTY TO BE INVALIDATED

The manufacturer cannot be held liable for any device use neglecting the indications provided in this manual. Remember that installation or maintenance other than those indicated in the manual can cause damages, injuries or fatal accidents.

↑ DANGER Unauthorised actions, tampering or modifications that do not follow the information provided in this manual can cause damages, injuries or fatal accidents and null and void the warranty.

ADANGER Read this manual carefully before device installation and maintenance and keep it for any further future consultation by the various operators.

↑ DANGER Extraordinary installation and maintenance must be performed by skilled and authorised technicians, with good knowledge of the refrigerating and electrical plants, according to the legal provisions in force in the country of use and in compliance with the norms concerning the plants and the safety requirements at the workplace.





Attention! Risk of fire and flammable materials. If the equipment uses R290 coolant, every possible precaution must be taken to avoid any danger related to the flammability of this gas.

During installation, the use of PPE (personal protective equipment) is fundamental, the identification and choice of adequate personal protective equipment is the responsibility of the employer or the workplace manager or the technician in charge of technical service. The identified devices must be worn by the operators. During ordinary use, gloves protect your hands from the cold pan. Below is a list of the main personal protective equipment (PPE) to be used during the various work operations:

OPERATION	PROTECTIVE CLOTHING	SAFETY FOOTWEAR	GLOVES	GOGGLES	CRASH HELMET OR SAFETY HELMET			
Transport and handling								
Unpacking								
Assembly								
Extraordinary cleaning								
Maintenance								
Disassembly								
Scrapping								
■ Mandatory personal protective equipment (PPE).								

☐ Personal protective equipment (PPE) to be used if necessary

Make sure the mains voltage and the frequency correspond to those specified in the specifications plate before connecting the device to the electrical mains.

DANGER Disconnect the mains before any cleaning or maintenance (turn the main switch to OFF and remove the plug).

DANGER THE MACHINE WAS NOT DESIGNED TO BE INSTALLED IN AN ATMOSPHERE WITH RISK OF EXPLOSION. Do not store explosive substances, such as pressurised flammable propellant containers, inside the appliance.

- Before installation, please check:
 - that the areas in which the machine will be installed are suitable for food preparation;
 - that the plants comply with the legal provisions in force in the country of use and meet the specifications on the serial number plate;
 - that appropriate ground fault protection devices are already in place according to the electrical safety regulations in force in the country of installation and/or destination;
 - that a point of connection to the water mains is near the device;
 - that a socket with a ground connection of the country of use type is arranged near the device;
 - the planarity of the device support area, especially if it is assembled on wheels.

During device installation:

- transit or permanence near the work area by individuals not assigned to device installation is prohibited;
- use the personal protection equipment (e.g. gloves, safety footwear, etc...);
- work according to workplace safety regulations (e.g. do not near electrical parts with wet hands or barefoot, etc...).

MARNING

ORIGINAL SPARE PARTS ARE RECOMMENDED. The manufacturer may not be held liable for the use of non original spare parts.

DANGER

Packaging material, since potentially hazardous, must be kept out of reach of children or animals and correctly disposed according to the local norms.

• The device is shipped after passing inspections: visual, electric and functional.

SAFETY WARNINGS FOR USE



FAILURE TO OBSERVE THE FOLLOWING RULES MAY RESULT IN DAMAGE AND INJURY, INCLUDING DEATH, AND MAY CAUSE THE WARRANTY TO BE INVALIDATED

Any use and type of cleaning performed that is not in compliance with those specified and intended in this booklet is considered as incorrect and may cause damage, injuries or fatal accidents, will void the warranty and will exempt the manufacturer from any responsibility.

The appliance may be used by children aged 8 years and over, and by persons with reduced physical, sensory or mental capacity, or who lack experience or the necessary knowledge, provided that they are being supervised and have received instructions concerning safe use of the appliance and an understanding of the hazards involved.

⚠ DANGER

Children must not play with the appliance. Cleaning and maintenance to be carried out by the user must not be performed by children without supervision.





Caution! Risk of fire and flammable materials. If the equipment uses R290 refrigerant, every possible precaution must be taken in order to avoid any danger related to the flammability of this gas.



Caution! Danger of electrocution. Do not approach electrical components with wet hands or bare feet.

ADANGER It is strictly forbidden to tamper with or remove the safety devices employed (protective grilles, danger stickers, etc.). The manufacturer declines all responsibility if the afore-mentioned instructions are not respected.

MARNING Do not insert screwdrivers or other tools between the protective devices (fan guards, evaporators, etc.). For the compressor and evaporator unit to function efficiently, never block the appropriate air intakes.

The identification and selection of appropriate personal protective Equipment). The identification and selection of appropriate personal protective equipment is the responsibility of the employer or of the person in charge of the workplace. The PPE identified must be worn by the operators. During ordinary use, gloves protect the hands from the cold pan. Below is a list of the main personal protective equipment (PPE) to be used during the various work operations:

OPERATION	PROTECTIVE CLOTHING	SAFETY FOOTWEAR	GLOVES	GOGGLES	CRASH HELMET OR SAFETY HELMET			
Ordinary use								
Routine cleaning								
■ Mandatory personal protective equipment (PPE)								
☐ Personal protective equipment (PPE) to be used if necessary								

<u>MARNING</u> Keep clear of obstruction all ventilation openings in the appliance enclosure or in the structure for building-in.

MARNING Do not use mechanical devices or other means to accelerate the defrosting process, other than those recommended by the manufacturer.

MARNING Do not damage the refrigerant circuit.

WARNING Do not use electrical appliances inside the food storage compartments of the appliance, unless they are of the type recommended by the manufacturer.

CORRECT USE OF THE EQUIPMENT

- This equipment is considered an agri-food machine (EC Regulation no. 1935/2004), intended to process food products in industrial and professional kitchens. It is not suited to store pharmaceutical, chemical or any other non-food product.
- Before starting and using the appliance, carefully wash its internal surfaces.
- In order to achieve the best performance from the equipment, it is necessary to observe the following instructions:
 - Do not place hot foods or uncovered liquids, live animals, miscellaneous objects or corrosive products inside the equipment
 - Wrap or otherwise protect food, particularly if it contains herbs or spices
 - Arrange the food items inside the equipment without impeding the air circulation and do not place paper, cardboard, chopping boards, etc. over the grilles, which could obstruct the air flow
 - Avoid frequent and prolonged door openings as much as possible
 - If the door has been opened and then reclosed, wait a few moments before reopening it
 - Maximum load pan or grille: 20kg | 44.1 lbs (GN 1/1) or 35 kg | 77.2 lbs (GN 2/1).
- The refrigeration equipment has been manufactured and designed with the appropriate precautions to ensure the health and safety of the user and does not present dangerous edges, sharp surfaces or elements protruding from the overall dimensions.

The equipment is guaranteed to be stable even with the doors open; it is, however, strictly forbidden to hang from the door(s).

INCORRECT USE OF THE EQUIPMENT THAT COULD REASONABLY BE PREDICTED

Any use other than those specified in this manual is incorrect. Incorrect use can lead to serious risks for the safety of users and damage to the equipment.

The following are considered reasonably predictable incorrect uses:

- Lack of maintenance, cleaning and routine checks on the equipment
- Structural modifications or changes to the operating logic
- Mishandling of protective covers or safety devices
- Non-use of PPE by operators, specialist staff and maintenance technicians

- Use of inappropriate accessories (e.g. use of unsuitable equipment, ladders)
- Storage, in the vicinity of the equipment, of combustible or flammable materials not compatible with or not relevant to production
- Incorrect installation of the equipment
- Putting into the equipment items and materials incompatible with its use or that might damage the equipment itself, harm people or pollute the atmosphere
- Climbing onto the equipment or hanging from the doors
- Non-observance of the instructions given about the intended use of the equipment
- · Leaving doors or drawers open or partly open, through forgetfulness or carelessness
- Positioning the product in spaces in such a way as to stop air circulating correctly or prevent doors/drawers closing properly
- Exceeding the weight of product allowed for each shelf/drawer.

RISKS ASSOCIATED WITH THE USE OF THE EQUIPMENT

CAUTION RISKS DUE TO MOVING IT ON WHEELS: if the equipment is fitted with wheels, be careful not to push it too forcefully whilst moving it, to avoid it tipping over and being damaged. Also take care with any unevenness of the surface it's moving across. Equipment that is on wheels has no levelling mechanism, so make sure that the supporting surface is perfectly horizontal and flat. Always lock the wheels with the devices provided.

ACAUTION RISKS DUE TO MOVABLE ELEMENTS: the only movable element is the fan, but it presents no risk because it is covered by a protective grille fastened with screws.



RISKS DUE TO HIGH/LOW TEMPERATURES: stickers saying "DANGER - TEMPERATURE" have been displayed in areas where there is the danger of high/low temperatures.



RISKS DUE TO ELECTRICITY: risks of an electrical nature have been solved by designing the electrical systems according to standard CEI EN 60335-1. Appropriate warning labels indicating "high voltage" identify the zones with dangers of an electrical nature.

Noise levels below 70 dB.

A DANGER Do not open more than one drawer or more than one shelf at the same time, in order to avoid the possibility of it tipping over.

INSTRUCTION FOR ETL AND FLAMABLE EQUIPMENTS

- The new hose-sets supplied with the appliance are to be used and old hose-sets should not be reused.
- Component parts shall be replaced with like components so as to minimize the risk of possible ignition due to incorrect parts.

WARNING! Use only spare parts wich are indicated on exploded drawings. Contact the Manufacturer.

- The appliance is to be installed in accordance with the Safety Standard for Refrigeration Systems, ANSI/ASHRAE 15.
- The appliance shall not be installed in public corridors or lobbies.

Qualification of workers

Every working procedure that affects safety means shall only be carried out by trained, recognized and licensed personnel for the task. Examples for such working procedures are:

- a) breaking into the refrigerating circuit;
- b) opening of sealed components;
- c) opening of ventilated enclosures.

Beginning work

Prior to beginning work on systems containing FLAMMABLE REFRIGERANTS, safety checks are
necessary to ensure that the risk of ignition is minimised. For repair to the REFRIGERATING SYSTEM, point from A) to point E) shall be completed prior to conducting work on the system.

A) Work procedure

• Work shall be undertaken under a controlled procedure so as to minimise the risk of a flammable gas or vapour being present while the work is being performed.

B) General work area

• All maintenance staff and others working in the local area shall be instructed on the nature of work being carried out. Work in confined spaces shall be avoided.

C) Checking for presence of refrigerant

The area shall be checked with an appropriate refrigerant detector prior to and during work, to
ensure the technician is aware of potentially toxic or flammable atmospheres. Ensure that the
leak detection equipment being used is suitable for use with all applicable refrigerants, i.e., nonsparking, adequately sealed, or intrinsically safe.

D) Presence of fire extinguisher

• If any hot work is to be conducted on the refrigerating equipment or any associated parts, appropriate fire extinguishing equipment shall be available on hand. A dry chemical or CO2 fire extinguisher should be adjacent to the charging area.

E) No ignition sources

• No person carrying out work in relation to a REFRIGERATING SYSTEM which involves exposing any pipe work shall use any sources of ignition in such a manner that it may lead to the risk of fire or explosion. All possible ignition sources, including cigarette smoking, should be kept sufficiently far away from the site of installation, repairing, removing and disposal, during which refrigerant can possibly be released to the surrounding space. Prior to work taking place, the area around the equipment shall be surveyed to make sure that there are no flammable hazards or ignition risks. "No Smoking" signs shall be displayed.

Ventilated area

Ensure that the area is in the open or that it is adequately ventilated before breaking into the
system or conducting any hot work. A degree of ventilation shall continue during the period that
the work is carried out. The ventilation should safely disperse any released refrigerant and preferably expel it externally into the atmosphere.

Checks to the refrigerating equipment

- Where electrical components are being changed, they shall be fit for the purpose and to the correct specification. At all times, the manufacturer's maintenance and service guidelines shall be followed. If in doubt, consult the manufacturer's technical department for assistance.
- The following checks shall be applied to installations using FLAMMABLE REFRIGERANTS:
 a) the actual REFRIGERANT CHARGE is in accordance with the room size within which the refrigerant containing parts are installed;

- b) the ventilation machinery and outlets are operating adequately and are not obstructed;
- c) if an indirect refrigerating circuit is being used, the secondary circuit shall be checked for the presence of refrigerant;
- d) marking to the equipment continues to be visible and legible. Markings and signs that are illegible shall be corrected:
- e) refrigerating pipe or components are installed in a position where they are unlikely to be exposed to any substance which may corrode refrigerant containing components, unless the components are constructed of materials which are inherently resistant to being corroded or are suitably protected against being so corroded.

Repair and maintenance

Repair and maintenance to electrical components shall include initial safety checks and component inspection procedures. If a fault exists that could compromise safety, then no electrical supply shall be connected to the circuit until it is satisfactorily dealt with. If the fault cannot be corrected immediately but it is necessary to continue operation, an adequate temporary solution shall be used. This shall be reported to the owner of the equipment, so all parties are advised. Initial safety checks shall include:

- a) that capacitors are discharged: this shall be done in a safe manner to avoid possibility of sparking;
- b) that no live electrical components and wiring are exposed while charging, recovering or purging the system;
- c) that there is continuity of earth bonding.

Repair sealed components

During repairs to sealed components, all electrical supplies shall be disconnected from the
equipment being worked upon prior to any removal of sealed covers, etc. If it is absolutely necessary to have an electrical supply to equipment during servicing, then a permanently operating form of leak detection shall be located at the most critical point to warn of a potentially
hazardous situation.

Work on electrical components

- Particular attention shall be paid to the following to ensure that by working on electrical components, the casing is not altered in such a way that the level of protection is affected. This shall include damage to cables, excessive number of connections, terminals not made to original specification, damage to seals, incorrect fitting of glands, etc.
- Ensure that apparatus is mounted securely.
- Ensure that seals or sealing materials have not degraded to the point that they no longer serve the purpose of preventing the ingress of flammable atmospheres. Replacement parts shall be in accordance with the manufacturer's specifications.

Repair to intrinsically safe components

- Do not apply any permanent inductive or capacitance loads to the circuit without ensuring that this will not exceed the permissible voltage and current permitted for the equipment in use.
- Intrinsically safe components are the only types that can be worked on while live in the presence of a flammable atmosphere. The test apparatus shall be at the correct rating.
- Replace components only with parts specified by the manufacturer. Other parts can result in the ignition of refrigerant in the atmosphere from a leak. NOTE The use of silicon sealant can inhibit the effectiveness of some types of leak detection equipment.
- Intrinsically safe components do not have to be isolated prior to working on them.

Cabling

• Check that cabling will not be subject to wear, corrosion, excessive pressure, vibration, sharp edges, or any other adverse environmental effects. The check shall also take into account the effects of aging or continual vibration from sources such as compressors or fans.

Detection of flammable refrigerants

- Under no circumstances shall potential sources of ignition be used in the searching for or detection of refrigerant leaks. A halide torch (or any other detector using a naked flame) shall not be used.
- The following leak detection methods are deemed acceptable for all refrigerant systems.
- Electronic leak detectors may be used to detect refrigerant leaks but, in the case of FLAMMABLE REFRIGERANTS, the sensitivity might not be adequate, or might need recalibration. (Detection equipment shall be calibrated in a refrigerant-free area.) Ensure that the detector is not a potential source of ignition and is suitable for the refrigerant used. Leak detection equipment shall be set at a percentage of the LFL of the refrigerant and shall be calibrated to the refrigerant employed, and the appropriate percentage of gas (25 % maximum) is confirmed.
- Leak detection fluids are also suitable for use with most refrigerants but the use of detergents
 containing chlorine shall be avoided as the chlorine can react with the refrigerant and corrode
 the copper pipe-work.

NOTE Examples of leak detection fluids are:

- bubble method.
- fluorescent method agents.
- If a leak is suspected, all naked flames shall be removed/extinguished.
- If a leakage of refrigerant is found which requires brazing, all of the refrigerant shall be recovered from the system, or isolated (by means of shut off valves) in a part of the system remote from the leak. Removal of refrigerant shall be according to chapter below "Removal and evacuation".

Removal and evacuation

- When breaking into the refrigerant circuit to make repairs or for any other purpose conventional procedures shall be used. However, for flammable refrigerants it is important that best practice be followed, since flammability is a consideration. The following procedure shall be
- · adhered to:
 - a) safely remove refrigerant following local and national regulations;
 - b) purge the circuit with inert gas;
 - c) evacuate:
 - d) purge with inert gas;
 - e) open the circuit by cutting or brazing.
- The refrigerant charge shall be recovered into the correct recovery cylinders if venting is not allowed by local and national codes. For appliances containing flammable refrigerants, the system shall be purged with oxygen-free nitrogen to render the appliance safe for flammable refrigerants. This process might need to be repeated several times.
- Compressed air or oxygen shall not be used for purging refrigerant systems.
- For appliances containing flammable refrigerants, refrigerants purging shall be achieved by breaking the vacuum in the system with oxygen-free nitrogen and continuing to fill until the working pressure is achieved, then venting to atmosphere, and finally pulling down to a vacuum. This process shall be repeated until no refrigerant is within the system.
- When the final oxygen-free nitrogen charge is used, the system shall be vented down to atmospheric pressure to enable work to take place.
- Ensure that the outlet for the vacuum pump is not close to any potential ignition sources and that ventilation is available.

Charging procedures

- In addition to conventional charging procedures, the following requirements shall be followed.
 - a) Ensure that contamination of different refrigerants does not occur when using charging equipment. Hoses or lines shall be as short as possible to minimise the amount of refrigerant contained in them
 - b) Cylinders shall be kept in an appropriate position according to the instructions.
 - c) Ensure that the REFRIGERATING SYSTEM is earthed prior to charging the system with refrigerant.
 - d) Label the system when charging is complete (if not already).
 - e) Extreme care shall be taken not to overfill the REFRIGERATING SYSTEM.
- Prior to recharging the system, it shall be pressure-tested with the appropriate purging gas. The system shall be leak-tested on completion of charging but prior to commissioning. A follow up leak test shall be carried out prior to leaving the site.

Decommissioning

- Before carrying out this procedure, it is essential that the technician is completely familiar with
 the equipment and all its detail. It is recommended good practice that all refrigerants are recovered safely. Prior to the task being carried out, an oil and refrigerant sample shall be taken in case
 analysis is required prior to re-use of recovered refrigerant. It is essential that electrical power is
 available before the task is commenced.
 - a) Become familiar with the equipment and its operation.
 - b) Isolate the system electrically.
 - c) Before attempting the procedure, ensure that:
 - i) mechanical handling equipment is available, if required, for handling refrigerant cylinders;
 - ii) all personal protective equipment is available and being used correctly;
 - iii) the recovery process is supervised at all times by a competent person;
 - iv) recovery equipment and cylinders conform to the appropriate standards.
 - d) Pump down refrigerant system, if possible.
 - e) If a vacuum is not possible, make a manifold so that refrigerant can be removed from various parts of the system.
 - f) Make sure that cylinder is situated on the scales before recovery takes place.
 - g) Start the recovery machine and operate in accordance with instructions.
 - h) Do not overfill cylinders (no more than 80 % volume liquid charge).
 - i) Do not exceed the maximum working pressure of the cylinder, even temporarily.
 - j) When the cylinders have been filled correctly and the process completed, make sure that the cylinders and the equipment are removed from site promptly and all isolation valves on the equipment are closed off.
 - k) Recovered refrigerant shall not be charged into another REFRIGERATING SYSTEM unless it has been cleaned and checked.

Labelling

Equipment shall be labelled stating that it has been de-commissioned and emptied of refrigerant. The label shall be dated and signed. For appliances containing FLAMMABLE REFRIGERANTS, ensure that there are labels on the equipment stating the equipment contains FLAMMABLE REFRIGERANT.

Removing refrigerant operations

When removing refrigerant from a system, either for servicing or decommissioning, it is recommended good practice that all refrigerants are removed safely. When transferring refrigerant into cylinders, ensure that only appropriate refrigerant recovery cylinders are employed. Ensure that the correct number of cylinders for holding the total system charge is available. All cylinders to be used are designated for the recovered refrigerant and labelled for that refrigerant (i.e., special

cylinders for the recovery of refrigerant). Cylinders shall be complete with pressure-relief valve and associated shut-off valves in good working order. Empty recovery cylinders are evacuated and, if possible, cooled before recovery occurs. The recovery equipment shall be in good working order with a set of instructions concerning the equipment that is at hand and shall be suitable for the recovery of all appropriate refrigerants including, when applicable, FLAMMABLE REFRIGERANTS. In addition, a set of calibrated weighing scales shall be available and in good working order. Hoses shall be complete with leak-free disconnect couplings and in good condition. Before using the recovery machine, check that it is in satisfactory working order, has been properly maintained and that any associated electrical components are sealed to prevent ignition in the event of a refrigerant release. Consult manufacturer if in doubt. The recovered refrigerant shall be returned to the refrigerant supplier in the correct recovery cylinder, and the relevant waste transfer note arranged. Do not mix refrigerants in recovery units and especially not in cylinders. If compressors or compressor oils are to be removed, ensure that they have been evacuated to an acceptable level to make certain that FLAMMABLE REFRIGERANT does not remain within the lubricant. The evacuation process shall be carried out prior to returning the compressor to the suppliers. Only electric heating to the compressor body shall be employed to accelerate this process. When oil is drained from a system, it shall be carried out safely.

RESIDUAL RISKS

 The correct design of the equipment and the installation of adequate protective devices do not completely eliminate the risks for the operator. This manual contains the list of personal protective equipment (PPE) that the employee must use. Sufficient space is provided during the installation phases of the equipment to limit the risks. To maintain these conditions, the areas surrounding the equipment must be kept clean, dry, well-lit and free from obstacles. Below is a list of the residual risks that remain on the machine.

RESIDUAL RISK	DESCRIPTION
Slipping or falling	The operator can slip due to the presence of water, oil or dirt on the floor.
Burns or abrasion	The user intentionally or unintentionally touches some of the components inside the equipment (e.g. cold trays, fins and cooling circuit tubes) without using protective gloves.
Electrocution	Contact with live electrical parts during maintenance operations carried out without disconnecting the power supply
Falling	The operator intervenes on the equipment using unsuitable systems to access the upper part.
Injuries	Specialist personnel may not properly secure the upper control console. The latter could detach and fall off.
Overturning	While moving the equipment and packaging using lifting and/or handling systems that are unsuitable or with the load unbalanced
Refrigerant gas	Inhalation of refrigerant gas. The type of refrigerant is shown on the equipment technical specifications plate

EMERGENCY SITUATIONS



CAUTION In the event of fire, do not use water, keep CO₂ (carbon dioxide) extinguishers to hand and cool the motor compartment as quickly as possible.

INSTALLATION

Product transport, handling

Warning markings are printed on the packaging. They indicate the limitations that must be observed to ensure safe device loading, unloading and transport.

Fig. 1 Device transport and handling must be done exclusively as follows:

- keep the packaging in the vertical position, as per the indications printed on it (this precaution is necessary to prevent the oil contained in the compressor from circulating, which may damage the valves and cause problems when starting the motor);
- use suitable handling means. Do not handle the goods by hand.
 If hoisting systems are used, such as forklifts or pallet jacks, the weight must be carefully balanced.

The packaging usually consists in polystyrene and stretch film on a wooden pallet, which is secured to the bottom of the device for safer transport and handling.

The manufacturer cannot be held liable for problems due to transport in conditions other than those previously specified.



PAY PARTICULAR ATTENTION TO THE PACKAGING IN-CLINATION DURING TRANSPORT SINCE THE DEVICE BARYCENTRE DOES NOT CORRESPOND TO ITS GE-OMETRICAL CENTRE.

Stacking limits

The devices, regardless of the model, CANNOT be stacked during transport or during storage.

Device check

Fig. 2 We recommend, after removing the packaging, you check device integrity and make sure it was not damaged during transport. If damage or anomalies are found, do not install the device and promptly inform the carrier. In any case, damaged devices cannot be returned to the manufacturer without prior notice and without prior written authorisation.



Fig. 3 AFTER UNPACKING, WHEN MOVING THE DE-VICE DO NOT PUSH IT OR PULL IT IN ORDER TO AVOID THE RISK OF OVERTURNING OR DAMAGING SOME PARTS (FOR EXAMPLE THE FEET).

NEVER TILT THE DEVICE FROM THE DOOR SIDE.

Systems preparation

Fig. 4 > Systems must comply with the legal provisions in force in the country of use and meet the specifications on the serial number plate.

There must be:

- A: a circuit breaker with high sensitivity (30 mA);
- B: a point of connection to the power mains;
- C: a point of discharge (optional).



Please see the specific chapters for their specifications (for example, the chapter "Electrical connection").

Characteristics of the installation area

Install the device in areas:

- compliant with industrial food handling;
- with adequate ventilation;
- prepared with electrical and plumbing systems compliant with the legal provisions in force in the country of use and according to the workplace safety requirements in the country of use;
- with temperatures from +15° to +43°C;
- that are sheltered against the elements;
- with flooring able to support the device at full load.

If the device is assembled on wheels (kit sold separately), it cannot be levelled. Therefore the surface must be perfectly horizontal, flat and completely smooth.

Protective film removal

Fig. 5 If the machine is intact, remove the protective film slowly.

Any glue residue can be removed with a proper solvent. Do not use tools or abrasive or strong detergents that might ruin the surfaces.



The removed protective films are potentially dangerous for children and animals. DO NOT LEAVE THEM UNATTENDED IN THE INSTALLATION AREA AND CORRECTLY DISPOSE OF THEM IN ACCORDANCE WITH LOCAL

STANDARDS.

Positioning

The machines must be positioned on the ground only, on floors:

- that are not sensitive to heat or flammables;
- perfectly levelled;
- with a regular surface and completely smooth;
- that can support the device at full load.

Fig. 6 Keep the illustrated minimum clearances around the device: this will facilitate connections to utilities and maintenance.

Fig. 7 Always check for perfect levelling: if this is not the case, rotate the feet until achieved.



DO NOT INSTALL THE DEVICE:

- NEAR OTHER MACHINES THAT REACH HIGH TEM-PERATURES (E.G. OVENS OR FRYERS);
- NEAR WALLS OR FURNITURE THAT IS EITHER FLAM-MABLE OR SENSITIVE TO HEAT.



Only use the manufacturer's wheel kit to make the device movable. For assembly, if necessary, read the instructions supplied with the kit.

Spacer installation

The devices require ventilation at the back, where the vents and refrigerating unit are found.

Therefore, do not place them against the wall but keep them approximately 5 cm away.

Fig. 8 \(\) In order to prevent accidental movements from shifting the device too close to the wall, install the provided spacers on the back of the device (especially if the device is assembled on wheels). Use supplied spacers and screws only.

Electrical connections



THE CONNECTION TO THE ELECTRICAL MAINS AND OTHER SUPPLIES MUST COMPLY WITH THE LEGAL PROVISIONS IN FORCE IN THE COUNTRY OF INSTAL-

LATION AND MUST BE PERFORMED BY QUALIFIED PERSONNEL AUTHORISED BY THE MANUFACTURER.



In order to avoid any risks, damaged power supply cables must be replaced by the Manufacturer, by an approved technical support centre, or in any case by an

individual with similar qualifications.

Before connecting the device to the mains:

- read the safety instructions provided at the beginning of this
- make sure the mains voltage and frequency correspond to those indicated in the device serial number plate. A rated voltage variation of +/-10% is accepted.



THE DEVICE MUST BE CONNECTED TO AN EFFICIENT GROUND SOCKET (=).



THE DEVICE MUST BE INCLUDED IN AN EQUIPOTEN-TIAL SYSTEM COMPLIANT WITH THE LEGAL PROVI-SIONS IN FORCE (YELLOW GREEN CONDUCTOR

WITH A MAXIMUM SECTION OF 10 MM2 - IEC EN 60335-2-42:2003-09 STANDARD). THIS CONNECTION MUST BE MADE BETWEEN VARIOUS DEVICES WITH THE TERMINAL MARKED WITH THE EQUIPOTENTIAL SYMBOL

For mains connections, use a circuit breaker with manual reset high sensitivity (30 mA), with adequate power that permits complete cut-off in over voltage category III conditions, in order to protect the device against over voltages or short circuits. For the sizing of the protection device, please refer to the technical data table at the end of the manual.

> Maximum storage values: 60°C Maximum transport values: 60°C Maximum values for the installation environment: 43°C Do not stack or store lying down.

Fig. 9 The single-phase appliances leave the factory with the power cable and an Unel plug already installed on the terminal block: it is not allowed to make any other type of electrical connection and no dimensional modification of the cable other than its lengthening, replacing it with one having the same characteristics as the original one (rubber type, section, etc.).

Plumbing connections




THE DRAIN MUST COMPLY WITH THE LEGAL PROVI-SIONS IN FORCE IN THE COUNTRY OF INSTALLATION AND MUST BE PERFORMED BY OUALIFIED PERSON-NEL AUTHORISED BY THE MANUFACTURER.

Outlet water


Cleansing water is collected in a tank which is under the machine. Fig. 10 We recommend you connect the drain to a flexible hose of maximum length 200 cm (not supplied) and lead it to a grate in the floor or wall drain pipe, to avoid empting the tank too frequently.


The drain pipe must have the following characteristics:


- is fitted with a trap;
- has a minimum inclination of 4%;
- has an air gap* of at least 25 mm;
- does not have clamps;
- has a diameter no less than that of the drain pipe coupling.






























USING THE CONTROLLER



- LED with decimal point function to display the time.
- LED with function of indicating the negative blast chilling cycle selected

steady on: LED which has the function of indicating the blast chilling cycle in

progress; flashing: LED which has the function of indicating the storage phase in progress

			DESCRIPTION
SET			
	Short press		Blast chiller start/stop operation and confirmation
DOWN	Short press		Slow decrease of the value and buzzer switch off During a program it displays the cell probe temperature
	Long press	x4 sec.	Fast decrease of the value and defrost activation
UP	Short press		Slow increase of the value and cell temperature display
+	Long press	₹ x4	Fast increase of the value and load activation on the auxiliary output (UV lamp for sterilization, needle probe heater or auxiliary condens- er fan)
	Short press		Positive/negative alternate program selection
SEL	Continuous press		Display of the elapsed time from the start of the blast chilling cycle or the duration of the blast chilling cycle until the key is released
	Long press	x4 sec.	Stand-by enable
DOWN+UP	Long press	x4 sec.	To access the configuration parameters press the DOWN and UP keys simultaneously for 4 seconds (only with blast chiller in stop phase or if there are no programs in progress).

Switch on

When the display switches on it performs a lamp-test (flashing of all segments and dots for 5 seconds).

When switched on for the first time, the display is in stand-by mode (three horizontal dashes "---" are shown on the display, one for each digit). The next time it is switched on, or when the power supply is restored, the blast chiller status varies depending on its status before the power supply failure.

If there is no program running, activate standby mode by pressing and holding **SEL** for 4 seconds.

Important information

The display shows programs for managing the following blast chiller functions:

positive blast chilling or cooling (automatic or manual), **negative blast chilling** or freezing (automatic or manual)



For automatic programs, the reference value is the temperature detected by the needle probe.

For manual programs, the reference value is the time.

Both the automatic program and the manual program include a blast chilling cycle, automatically followed by a storage phase, which is positive or negative depending on the cycle chosen. At the end of the blast chilling cycle, when the storage phase starts automatically, a buzzer sounds intermittently (this can be

modified by the user under parameter P 0). To silence the buzzer in advance, press the DOWN key.

During the execution of a program:

- the LED L2 is off if a positive blast chilling cycle was selected, or is on if a negative blast chilling cycle was selected;
- the **L3 LED** is on during the blast chilling cycle and flashing during the storage phase;
- pressing the **UP** key determines the display of the temperature measured by the cell probe for a duration of 5 seconds;
- pressing and holding the **SET** key determines, until the key is released, the display of the time elapsed since the start of the blast chilling cycle if the blast chilling cycle is still in progress, the duration of the previous blast chilling cycle if the storage phase is in progress.

At the end of a program, before starting the next program, the display shows the data relative to the last program run.

Automatic program

To select and start an automatic program (Fig. 8) proceed as described below:

- Press the SEL key until the display shows the **positive blast chilling** cycle (default +3°C - P13 parameter) or **negative blast chilling** cycle (default -18 °C - P14 parameter).




The repeated pressing of the SEL key causes the display to alternately flash between the value set for the posi-

tive blast chilling cycle and the value set for the negative blast chilling cycle.

- Wait 5 seconds or press the **SET** key to confirm (the temperature display becomes fixed).
- Press the SET key to start the program: during the execution of an automatic program the display shows the temperature measured by the needle probe.



The temperature parameters can be modified by the



At the end of the blast chilling cycle the display shows the temperature measured by the needle probe, flashing if the target set has not been reached (P13 -P14 parameters).

The duration of the blast chilling cycle is determined by one of the following conditions:

- reaching the selected temperature setpoint (P13 -P14 parameters):
- exceeding the set time, even if the temperature has not been reached (parameters P19-P20).

At the end of the blast chilling cycle, the **storage** phase starts (signalled by a beep). The temperature measured by the cell probe is shown on the display.

Storage phase characteristics:

- after a positive blast chilling cycle (parameter P19) room temperature setting equal to the value set for parameter P17;
- after a negative blast chilling cycle (parameter P20) ▶ room temperature setting equal to the value set for parameter P18.

Manual program (by time)

To select and start a manual program (Fig. 9) proceed as described below:

- press the **SEL** key until the display shows the **positive blast chilling cycle** (display of P13 parameter, default +3 °C) or negative blast chilling cycle (display of P14 parameter, default -18 °C).



The repeated pressing of the SEL key causes the display to alternately flash between the value set for the positive blast chilling cycle and the value set for the negative blast chilling cycle.

- Wait 5 seconds or press the SET key to confirm (the temperature display becomes fixed).
- Press the UP or DOWN key to select the duration of the blast chilling cycle (the starting value displayed is the one set by default, parameter P19 or P20 respectively for positive blast chilling cycle or negative blast chilling cycle).



The cycle time modification is not permanent (it does not change the default values for parameters P19 and P20). When the cycle is next set, the default values set under parameters P19 and P20 will be shown again.

- Wait 5 seconds or press the SET key to confirm (the cycle time display becomes fixed).
- Press the SET key to start the program. During the blast chilling cycle the display shows the total cycle time (parameter P19 or P20 respectively for positive blast chilling cycle or negative blast chilling cycle).




The time is displayed in the form of a decimal number, where the integer part represents the hours and the decimal part represents the minutes (for example, "1.30" indicates the time 90 minutes, i.e. 1 hour and 30 minutes).

At the end of the blast chilling cycle, the **storage** phase starts (signalled by a beep). The temperature measured by the cell probe is shown on the display.

Storage phase characteristics:

- after a positive blast chilling cycle (parameter P19) room temperature setting equal to the value set for parameter P17;
- after a negative blast chilling cycle (parameter P20) ▶ room temperature setting equal to the value set for parameter P18.8.



Selecting and starting special functions

The appliance is provided with special functions to manage the following blast chilling functions:

- manual defrost,
- **cell sterilization** (optional, if provided by the blast chiller),
- needle probe heating (optional, if provided by the blast chiller).

The storage phase starts automatically at the end of the special function and the buzzer will sound intermittently for the set time (this can be modified by the user under parameter P 0). To silence the buzzer in advance, press the DOWN key.

Manual defrost

Defrosting is normally performed by the User with the blast chiller door open (cell heating). Door opening or closure has no effect on the defrost process.

To start defrosting press and hold the **DOWN** key for 4 seconds.



The defrost configuration and duration are determined by the parameters P 5, P 7, P11, which can be modified by the User. During the defrost, the display shows the "dEF" string.

Cell sterilization

Sterilization can be enabled if the value of parameter P23 is equal to 1. To activate a sterilization cycle there must be no program or other special function in progress and the blast chiller door must be closed.

To start the sterilization cycle hold down the ${\bf UP}$ key for 4 seconds.



The sterilization cycle start and duration are determined by the parameters P 8, P24, P25, which can be modified by the User. During the sterilization cycle the display shows the "StE" string.

In the case of a cell probe error "Er2":

- before the sterilization cycle start, the sterilization cycle does not start;
- during the sterilization cycle, the sterilization cycle continues normally.

If at start-up or during the sterilization cycle the cell temperature is lower than the reference value (parameter P25), the display will show the "cLd" string.a.

Needle probe heating

Needle probe heating can be activated if the value of parameter P23 is equal to 2. Door opening or closure has no effect on needle probe heating. To activate needle probe heating there must be no program or other special function in progress.

To start needle probe heating hold down the UP key for 4 seconds.



The needle probe heating configuration is determined by the parameters P28 and P29, which can be modified by the User. During needle probe heating, the display shows the "Prb" string.

Stopping and restarting a program or a special function

During the execution of a program or a special function, press the **SET** key to stop it.

If a program has been completed, press the **SET** key again to restart from the point in which it was interrupted.



If the restarted program is of the manual type, the cycle starts from the beginning for the set cycle time.

If a special function was not completed, it is not possible to restart from the point where it was interrupted.

What does a blast chiller do?

A blast chiller is a device that quickly lowers the temperature of the introduced food, whether fresh or cooked.

Fresh or just cooked food has the best sensory qualities and flavour; however, if not eaten immediately, it loses its initial qualitative properties and is subject to the proliferation of micro-organisms, which are potentially harmfuly to humans.

Positive Chilling is used when food is not eaten within two hours of its preparation, reducing the product temperature to $+3^{\circ}$ C at the core within 90 minutes. Subsequently, the product must be stored in a refrigerator at a temperature between $0/+3^{\circ}$ C where it can be kept for up to 5 days.

Negative Chilling is used to keep all the sensory properties of the food intact. The chiller reduces the product temperature until reaching -18° C at its core. Subsequently, the product must be stored in a freezer at a constant temperature of -20 degrees and can even be eaten after 3/18 months, according to the product, provided the cold chain regulations are met.

Storage is the next step in the blast chilling cycle, in which the food product is maintained at a certain temperature in order to preserve its cooling or freezing. It is divided into:

Positive storage, in the case of cooling; **Negative storage**, in the case of freezing.

Normal refrigerators and freezers, unlike a blast chiller, are unable to rapidly lower the initial temperature of the product, which is therefore damaged in terms of its sensory properties and flavour.

Correctly loading the equipment

Food should be placed in a single layer in containers:

- that are uncovered;
- that are food-safe;
- that are resistant to the temperatures reached by chilling;
- that have low edges (maximum 4.5 cm).

Containers should be evenly placed inside the cell.

Correct container placement will allow free air circulation in the cell: avoid obstructing the air vents and overloading the equipment beyond the admissible limits.

Achieving better results and working in safe conditions

- Fig. 11 Keep the motor compartment air vents free of objects and remove dust;
- periodically clean and replace the filter behind the motor compartment air vents:
- arrange food to be chilled or cooked as explained in the previous chapter;
- accurately close the doors during each work cycle;
- always keep the defrost water drain hole free;
- avoid opening doors during positive/negative chilling;
- perform routine maintenance as indicated in the specific section;

How to use the needle probe

Fig. 12 The needle probe, during chilling, reads the temperature at the food "core": when it reaches the value set by the user or default value, it means the food is chilled (**Chilling** function). The needle probe is fully inserted in the food to be chilled: make sure its tip reaches the food "core", meaning the most internal point, without exiting.

Be careful not to insert it in very fatty points and near bones. In case of very thin food products, insert the probe parallel to the support surface.

Always keep the probe clean and sanitised.



HANDLE THE PROBE WITH CARE INSOFAR AS IT IS

Noise level

 L_{∞} in the noisiest part at 1m in working conditions < 70 dB(A)

L_{pc} at 1m in working conditions

< 130 dB(C)

Test environment

Tests were conducted in a rectangular exposure room without sound insulation. There were no significant obstacles near the machine.

Standards


The sound tests were carried out in compliance with Legislative Decree 277 following the methods described in ISO 230-5 to obtain the data required by directive 2006/42/EC.


Machine operating conditions

The tests were conducted in the most severe conditions, which correspond to the starting phase called "PULL DOWN".

Materials and fluids used


To ensure environmental protection, the materials used are compliant with Legislative Decree no. 151, 25th July 2005, in implementation of the RoHS (2002/95/EC) and WEEE (2002/96/EC and 2003/108/EC) directives, concerning the reduction of hazardous substance use in electrical and electronic devices, as well as waste disposal. Coolant gases or polyurethane foam expanding gases used comply with Regulation EC 842/2006.






Performance characteristics of blast chill and sh	SB-031-RA-HC	
Capacity chill -120'	+65/+10°C ISO 22042	5 kg/11 lbs
Capacity freeze -270'	+65/-18°C ISO 22042	5 kg/11 lbs
Pan capacity	3 X GN 1/1	
Min. distance between tray holder centers	69mm/2.72 in	

Chilly R290 ISO 22042 +65/+10 °C



Chilly R290 ISO 22042 +65/-18 °C



				According to Standard ISO 22042			
Power Supply		Yield per Cycle		Yield per Cycle		Consumption for Cycle	
Model	(V/ph/Hz)	BC +90/+3°C +194/+37°F	BF +90/-18°C +194/0°F	BC +65/+10°C +149°F/+50°F	BF +65°C/-18°C +149°F/0°F	ВС	BF
		(kg/lbs)	(kg/lbs)	(kg/lbs)	(kg/lbs)	(kW)	(kW)
SB-031-RA-HC	115/1N~/60	8/17.6	5/11	5/11	5/11	0.64	1.98

Model	Electric Power	Electric Absorption	Gas Type	Net Weight (kg/lbs)	Gross Weight (kg/lbs)	Width (mm/inch)	Depth (mm/inch)	Height (mm/inch)	Number of Trays
SB-031-RA-HC	629	3.25	R-290	52/115	58/128	625/24.6	700/27.6	600/23.62	3 X GN 1/1

MAINTENANCE AND CLEANING

MAINTENANCE



BEFORE PERFORMING ANY MAINTENANCE, CUT OFF THE POWER SUPPLY TO THE MACHINE AND WEAR SUITABLE PERSONAL PROTECTIVE EQUIPMENT (E.G. GLOVES, ETC.).



THE USER MUST ONLY PERFORM ROUTINE MAINTE-NANCE OPERATIONS (MEANING CLEANING). FOR EXTRAORDINARY MAINTENANCE, CONTACT A SER-

VICE CENTRE REQUESTING SERVICE FROM AN AUTHORISED TECHNICIAN.



THE WARRANTY IS NULL AND VOID IN THE EVENT OF DAMAGES DUE TO NEGLIGENT OR INCORRECT MAIN-TENANCE (E.G. USE OF UNSUITABLE DETERGENTS).

Fig. 13 To clean any components or accessories, DO NOT use:

- abrasive or powder detergents;
- aggressive or corrosive detergents (e.g. hydrochloric or sulphuric acid, caustic soda, etc.). Warning! Do not use these substances even to clean the floor under the equipment;
- abrasive or sharp tools (e.g. abrasive sponges, scrapers, steel brushes, etc.);
- steamed or pressurised water jets.

At first use, wash the trays and chamber using a cloth dampened with hot soapy water and end with rinsing and drying. To eliminate work residue, run the equipment empty for about 30 min-

External steel surface cleaning

Fig. 14 Use a cloth dampened with hot soapy water or specific products for steel. End with rinsing and drying.

Equipment chamber cleaning

Clean the equipment chamber daily to maintain high levels of hygiene and equipment performance.

Always use a cloth dampened with hot soapy water and end with rinsing and drying.

Touch screen

Use a cloth slightly dampened with a product specific for glass following the instructions of the manufacturer of the detergent. Do not spray too much product to avoid infiltrations that could damage the display.

Vent cleaning

Fig. 15 Keep vents free of obstructions and dust, cleaning them often with a normal vacuum or brush.

Fig. 16 We recommend you remove the front panel once a week following the illustrated instructions and clean the filter with hot soapy water. If replacement is required, contact the manufacturer to order spare parts.

Disuse

In the event of disuse, cut off the electrical and water supply. Protect external parts in steel by wiping them down with a soft cloth slightly dampened with Vaseline oil. Leave the door ajar to guarantee correct ventilation.

Before resuming operations:

- accurately clean the equipment and accessories;
- reconnect the equipment to the power and water mains;
- inspect the equipment before using it;
- restart the equipment at a low temperature for at least 60 minutes without any food inside.



To ensure that the device is in perfect use and safety conditions, we recommend you have it maintained and serviced by an authorised service centre at least once a year.

Disposal at end of service life

As per Legislative Decree no. 49 art. 13 dated 2014 "Implementation of WEEE Directive 2012/19/EU on electric and electronic waste"



The barred bin marking specifies that the product was released onto the market after August 13, 2015 and should not be assimilated with other waste at the end of its service life but disposed of separately.

All equipment is made of recyclable metallic materials (stainless steel, iron, aluminium, galvanised sheet metal, copper, etc.) in percentages over 90% in weight.

Put the equipment out of order for disposal removing the power cord and any compartment or chamber lock devices (where applicable). Pay attention to managing this product at the end of its service life, reducing negative impacts on the environment and improving resource use efficiency, applying the "who pollutes pays", prevention, reuse, recycling and recovery preparation principles. Please remember that illicit or incorrect product disposal is punishable by law.

Information on disposal in Italy

WEEE equipment in Italy must be delivered to:

- collection centres (also called ecological islands or platforms)
- the dealer where new equipment is purchased, who must collect it free of charge ("one to one" collection);


Information on disposal in European Union countries


The Community Directive on WEEE equipment has been assimilated in different ways in each country. Therefore we suggest you contact your local authorities or Dealer to request the correct disposal method.





While awaiting dismantling and disposal, the equipment can be temporarily stored even outdoors, provided the electrical, refrigeration and plumbing circuits are intact and closed. Also make sure the doors cannot be

closed to avoid entrapment. Follow the environmental protection laws in the user's country.









Beverage-Air

METHODS FOR CLEANING STAINLESS STEEL

Cleaning Needed	Cleaning Agent	Method of Application	Affect on Finish
Smears and fingerprints	Areal 20, Lac-O-Nu, Lumin Wash O'Cedar Cream Polish, Stainless Shine.	Rub with cloth as directed on the package.	Satisfactory for use on all finishes. Provides barrier film to minimize prints.
	Allchem Concentrated Cleaner.	Apply with damp sponge or cloth. Rub with damp cloth.	
	Samae, Twinkle or Cameo Copper Cleaner	Rub with damp cloth.	
	Grade FFF Italian pumice, whiting, or talc.	Rub with dry cloth.	
Stubborn Spots and Stains, Baked-On Splatter, and Other Light Discolorations	Liquid NuSteel Paste NuSteel or DuBois Temp. Copper's Stainless Steel Cleaner Revere Stainless Cleaner Household cleansers, such as Old Dutch, Lighthouse, Sunbrite, Wyandotte, Bab-O, Gold Dust, Sapolio, Bon Ami, Ajax, or Comet Grade F Italian Pumice, Steel Bright, Lumin Cleaner, Zud, Restore, Sta-Clean, or Highlite. Penny-Brite or Copper-Brite.	Use small amount of cleaner. Rub with dry cloth using a small amount of cleaner. Apply with damp sponge or cloth. Rub with a damp cloth. May contain chlorine bleaches. Rinse thoroughly after use. Rub with a damp cloth. Rub with a dry cloth using a small amount of cleaner.	Use in direction of polish lines on No. 4 (polished) finish. May scratch No. 2 (mill) and Nos. 7 and 8 (polished) finishes.
Heat tint or discoloration	Penny-Brite or Copper-Brite. Past NuSteel, DuBois Temp, or Tarnite. Revere Stainless Steel Cleaner. Allen Polish, Steel Bright, Tenacious Deposits, Rusty Discolorations, Industrial Atmospheric Stains Wyandotte, Bab-O or Zud.	Rub with a dry cloth. Rub with a dry cloth or stainless steel wool. Apply with damp sponge or cloth. Rub with a damp cloth.	
Burnt-On Foods and Grease Fatty Acids, Milkstone (where swabbing or rubbing is not practical)	Easy-Off, De-Grease-It, 4 to 6% hot solution of such agents as trisodium phosphate or sodium tripolyphosphate or 5 to 15% caustic soda solution	Apply generous coating. Allow to stand for 10-15 minutes. Rinse. Repeated application may be necessary.	Excellent removal, satisfactory for use on all finishes.
Tenacious Deposits, Rusty Discolorations, Industrial Atmospheric Stains	Oakite No. 33, Dilac Texo 12, Texo NY, Flash-Klenz, Caddy Cleaner, Turco Scale 4368 or Permag 57.	Swab and soak with clean cloth. Let stand 15 minutes or more according to directions on package, then rinse and dry.	Satisfactory for use on all finishes
Hard Water Spots and Scale	Vinegar. 5% oxalic acid, 5% sulfamic acid, 5 to 10% phosphoric acid, or Dilac, Oakite No. 33, Texo 12, Texo N.Y.	Swab or wipe with cloth. Rinse with water and dry. Swab or soak with cloth. Let stand 10-15 minutes. Always follow with neutralizer rinse, and dry.	Satisfactory for all finishes. Satisfactory for all finishes. Effective on tenacious deposits or where scale has built up.

IN CASE OF EQUIPMENT MALFUNCTION

▲ CAUTION If the equipment does not work or you notice functional or structural changes, disconnect it from all the mains supplies and contact a service centre authorised by the manufacturer, without attempting to repair it yourself.

⚠CAUTION Be sure to use original spare parts. The manufacturer declines any responsibility for the use of non-original spare parts.

• To ensure that the equipment is maintained in perfect conditions for use and safety, we recommend that a service and inspection be carried out by an authorised service centre at least once a year.R452a / R448a / R290 REFRIGERANT GAS WARNINGS

The volume of the room where the equipment is located must be greater than one cubic meter to allow dispersion of the gas.

GAS CHARACTERISTICS

R290	R452a	R448a
propane chemical formula: C3H8	Pentafluoroethane (HFC R125), 2,3,3,3-Tetrafluoroprop-1-ene (HFO R1234yf), Difluoromethane (HFCR32) chemical formula: C2HF5+C3H2F4+CH2F2	Difluoromethane (HFC R32), Pentafluoroethane (HFC R125), 1,1,1,2-Tetrafluoroethane (HFC R134a), 2,3,3,3-Tetrafluoroprop-1-ene (HFO R1234yf), trans-1,3,3,3- Tetrafluoroprop-1-ene (HFO R1234ze) chemical formula:
		CH2F2+C2HF5+C2H2F4+C3H2F4
		+C3H2F4
Global warming potential (GWP) = 3.	Global warming potential (GWP) = 2141.	Global Warming Potential (GWP) = 1387
Ozone destruction potential (ODP) = 0.	Ozone destruction potential (ODP) = 0.	Ozone Depletion Potential (ODP) = 0.
Safety classification: A3. Non-toxic but extremely flammable. The substance is regulated by the Montreal Protocol (1992 revision).	The substance is regulated by the Montreal Protocol (1992 revision)	The substance is regulated by the Montreal Protocol (1992 revision)

HAZARD IDENTIFICATION

R290	R452a	R448a
	bot surfaces sparks paked flames	Protect from sunlight and do not

Low concentrations can cause narcotic effects with possible loss of consciousness, dizziness, headaches, nausea and loss of coordination.

High concentrations can cause asphyxiation due to reduced oxygen content in the atmosphere. Very high concentrations can cause abnormalities of the heart rhythm and sudden death.

The sprayed or splashed product may cause skin burns and serious eye damage. It is unlikely to be dangerous by skin absorption. Repeated or prolonged contact can cause the removal of skin fat, resulting in dryness, chapping and dermatitis.

FIRST AID MEASURES

If the person is unconscious, place them on their side in a stable position and consult a doctor. Do not give anything to unconscious persons. In case of irregular breathing or respiratory arrest, practice artificial respiration. In case of persistence of the disorders or symptoms consult a doctor.

Inhalation: remove the injured person from exposure by wearing the breathing apparatus, take them to a warm place and keep them lying down. If necessary, practice artificial respiration, administer oxygen or perform cardiac massage. Seek immediate medical attention.

Skin contact: defrost the affected areas with water. Remove contaminated clothing, as it may adhere to the skin in case of frostbite. Immediately and abundantly wash the affected areas with warm water. If skin irritation or blistering occurs, seek medical attention.

Eye contact: check if the injured person is wearing contact lenses. If this is the case, remove them, wash the eyes immediately with clean water, keeping the eyelids blinking, for at least 15 minutes. Do not apply ointments or oil. Seek medical attention.

Ingestion: do not induce vomiting! If the injured person is conscious, rinse the mouth with water and drink 200-300 ml of water. Seek immediate medical attention.

Additional medical care: symptomatic treatment and supportive care when indicated. Do not administer adrenaline and similar sympathomimetic drugs following exposure due to the risk of cardiac arrhythmia with possible cardiac arrest.

FIRE-FIGHTING MEASURES

R290	R452a	R448a
Highly flammable gas.	Non-flammable.	



Keep unprotected persons away and evacuate them to safe areas.



To extinguish any fire, always use a self-contained respirator and appropriate protective clothing (e.g. protective gloves or goggles).



Incomplete thermal decomposition causes the emission of very toxic and corrosive vapours (carbon monoxide).

Cool the motor compartment area as quickly as possible.

An explosive re-ignition may occur. Extinguish all surrounding flames.

Move any combustible objects away from the fire area if this can be performed safely.

What to use to extinguish the fire: alcohol-resistant foam, dust and CO_2 carbon dioxide, water spray to reduce or remove the fumes.

What NOT to use to extinguish the fire: strong jets of water

ACCIDENTAL SPILLS

R290 R452a R448a



Keep unprotected persons away and evacuate them to safe areas. Immediately ventilate the area following the local safety plan. Do not touch or inhale the leaked gas.



Disconnect the power cord of the equipment from which the gas is escaping.



For the management of spills, wear suitable respiratory protection devices with air reserve, gloves and protective goggles. Avoid the inhalation of vapours. Atmospheric concentrations must be kept to a minimum and kept to the minimum reasonably possible level, below the occupational exposure limit.

Vapours are heavier than air and therefore high concentrations could form near the ground where general ventilation is poor.

Avoid contact with naked flames and hot surfaces because irritating and toxic decomposition products may form or, in the case of flammable gases (R290), explosions and fires.

Disposal of the leaked gas must be carried out by authorised and qualified centres.

If in doubt, contact the local authorities for additional information.

When the emergency is over, contact the technical assistance for repair of the machine.

R290	R452a	R448a
Minor leaks: do not attempt to stop the gas leak. Leaks of significant magnitude:	Minor leaks: if the conditions are surventilation, isolate the source of tevaporate safely.	
contain spilled material with sand, soil or other suitable absorbent material. Prevent liquid	<u>Leaks of significant magnitude</u> : co soil or other suitable absorbent ma drains, sewers, basements and wo can create a suffocating atmosphe	terial. Prevent liquid from entering orking holes because the vapours
Consider that R290 gas is highly flammable.		

DISPOSAL

It is strictly forbidden to discharge this refrigerant into the atmosphere which must be properly recovered, treated or disposed of following the legal procedures, using qualified and enabled personnel. If in doubt, contact the local authorities for additional information. The best solution is to recover and recycle the product: if this is not possible, destruction must take place at an authorised plant equipped to absorb and neutralise acid gases and other toxic processing products.

ALARM CODES

The appliance is able to perform a complete diagnostics of the blast chiller, reporting any malfunctions with specific alarms, showing the related code on the display. No beep sounds when an alarm occurs. The following table lists the alarms, with related code, indicating the causes, effects and solutions.

	ALARM	CAUSE	EFFECTS	SOLUTIONS
Er1*	Needle probe error	Needle probe not connected properly	If an automatic program is in progress, switch to manual	Check the connection of the needle probe to the appliance
		Faulty needle probe	program	Replace the needle probe
		Cell proble not connected properly	If a manual program is in progress with the needle probe (parameter P 3=1), the manual program	Check the connection of the cell probe to the appliance
Er2*	Cell probe error	Cell probe failure	continues using the needle probe as a cell probe If a manual program is in progress without the needle probe (parameter P 3=0), the manual program stops If an automatic program is in progress, the automatic program stops	Replace the cell probe
Er3	Condenser	Condenser probe not connected properly	. /	Check the connection of the condenser probe to the appliance
CI3	probe error	Condenser probe failure	,	Replace the condenser probe
Er4	Auxiliary Er4 condenser probe error	The auxiliary condenser probe is not connected properly	/	Check the connection of the auxiliary probe to the EWBC1400
	Auxiliary condenser probe failure		-	Replace the auxiliary probe
dOr	Door open	Blast chiller door opening with program or special function (except defrost) in progress		Close the blast chiller door to resume the program normally
Prs	Pressure switch alarm without load locking	 Opening of the pressure switch DI2 (if parameter P27 is different to 0) Pressure switch alarm events count <parameter li="" p27<=""> </parameter>	Increase by one unit of the alarm counter (initially zero) Blast chiller in stand-by status: - compressor deactivation (OUT1) - cell fan deactivation (OUT2) - condenser fan activation (OUT4), if parameter P23=3 - time count suspended, if a manual program is in progress	and wait for the compressor safety times (parameter P 9 and
-	Pressure switch alarm with load locking	Opening of the pressure switch DI2 (if parameter P27 is different to 0) pressure switch alarm events count = parameter P27	Deactivation of all loads (OUT1, OUT2, OUT3, OUT4)	Press the SET key**

^{*} Er1, Er2 not displayed if EWBC1400 is in stand-by mode.

^{*} When the SET key is pressed the program or the special function in progress stops and the alarm events count is reset. When switched on, EWBC1400 indicates the pressure switch alarm "PrS" if the DI2 pressure switch is open, as this input is normally closed (NC). The pressure switch alarm has priority over the open door alarm.

The following table summarizes the different display views depending on the alarms that occur, if the display shows the PB1 probe temperature. The vewing on the display of the probe PB1 temperature is equal to 40°C.

TYPE OF ERROR	DISPLAY
None (continuous display of the probe PB1 temperature)	40
Probe PB1 error (continuous display of "Er1"). If probe PB2 temperature is displayed, cyclic display in succession of "Er1" and probe PB2 temperature	E - 1
Probe PB2, PB3 and PB4 error (e.g. probe PB3 error: cyclic display in succession of "Er3"-"40")	40 ₹ 8 € 3
Error of two probes, one of which is PB1 (e.g. probe PB1 and PB3 error: cyclic display in succession of "Er3"-"Er1")	Er!≠Er3
Error of two probes, excluding PB1 (e.g. probe PB2 and PB3 error: cyclic display in succession of "Er3"-"40"-"Er2"-"40")	\
Error of three probes, one of which is PB1 (e.g. probe PB1, PB2 and PB3 error: cyclic display in succession of "Er1"-"Er3"-"Er1"-"Er2")	Er!→Er3 ↑ ↓ Er2←Er!
Error of three probes, excluding PB1 (probe PB2, PB3 and PB4 error: cyclic display in succession of "Er2"-"40"-"Er3"-"40"-"Er4"-"40")	
Open door, with P $1=1$ (continuous display of "dOr"; each time the SET key is pressed, "40" or "dOr" is displayed alternately.)	SET OUR.
Open pressure switch with P27 different to 0 and alarm events count less than P27 (flashing display of "PrS"; every time the SET key is pressed "40" or "PrS" are displayed alternately)	- P - S - 40
Open pressure switch with P27 different to 0 and alarm events count equal to P27 (continuous display of "PrS")	Prs

Problem type	Before contacting a service centre, check that	
The device is fully off.	the system is powered and the plug is not disconnected.	
The equipment does not cool enough	it is not affected by an external heat source; the doors are fully shut; the condenser filter is not clogged; the front air vents are not obstructed by objects or dust; food is well distributed in the cell and does not obstruct ventilation in the cell; the equipment is not overloaded with food (follow your equipment load instructions).	
The equipment is very noisy	there is no contact between the equipment and any other object or machine; the equipment is perfectly levelled; visible screws are well-tightened.	

LOCATING THE SERIAL PLATE

The data plate is positioned externally, on the side or back of the device, and internally in the motor compartment. The rating plate provides important technical information: this is essential in case of device maintenance or repairs: we recommend you do not remove, damage or modify the plate.

If the equipment does not work or functional or structural alterations are noted:

- disconnect it from the power and water mains;
- -consult the table on page 33 to check the proposed solutions;


If the solution is not found in the table, contact a manufacturer's authorised service centre communicating:


- the nature of the defect;
- the equipment code and serial number found on its specification plate


Require original spare parts for repairs: the manufacturer cannot be held liable and null and voids the warranty in the event non original spare parts are used.



To ensure that the appliance is in perfect use and safety conditions, we recommend you have it maintained and serviced by an authorised service centre at least once a year.









Serial number plate details

- 1 Manufacturer
- 2 Serial number
- 3 Code
- 4 Model
- 5 Voltage
- 6 Current absorbed during operation
- 8 Absorbed power
- 9 Power of the defrosting resistance
- 10 Rated power of other resistances
- 11 Lamp power
- 12 Maximum and minimum pressure
- 13 Coolant, type and quantity
- 15 Insulation blowing gas
- 16 Year of manufacture
- 17 Climate class (#)

FOR THE SERVICE TECH - WIRING DIAGRAM





FOR THE SERVICE TECH - WIRING DIAGRAM LEGEND

A	Power supply unit
Aı	Lamp power supply unit
A2	Printer power supply unit
В	Probe
B1	Temperature probe
B2	Defrosting probe
В3	Core probe
B4	Condenser probe
В5	Vacuum probe
В6	Humidity probe
\vdash	
B ₇	Evaporator outlet temperature probe
B8	Surface probe
BX	Sanitizing
С	Electric condenser
CK	Buzzer
D	Voltage variator
D116	Quick connector
Е	Thermostat
E1	Safety thermostat
E2	Control thermostat
EEV	Electronic expansion valves
EVD	EEV control module
FU	
\vdash	Fuse
G	Thermostat
G1	Power card
G2	Command card
G3	Auxiliary card
G4	Printer + IF RICS
G ₅	Fan control
G6	Encoder
Н	Indicator light
Hı	Power indicator light
H2	Alarm indicator light
Нз	Defrosting indicator light
H4	Cycle indicator light
IG	Main switch
I1	Switch
I2	Switch
I3	Door microswitch
I4	
$\overline{}$	Float
I5	Selector
16	Evaporator micro switch
K1	Compressor contactor
K2	Condenser contactor
Кз	Evaporator fan contactor
K4	UVC contactor
К5	Defrosting contactor
К6	Delayed contact
К8	Room heating contactor
KA	Auxiliary relay
L	Line
Lı	3-phase line #1
L2	3-phase line #2
L ₃	3-phase line #3
M	
	Electric motor
M1	Compressor
M2	Condenser fan
М3	Evaporator fan
M4	Additional motorised fan
M5	Linear actuator
М6	Heating and dehumidification fan

EG		ND
N	1	Neutral
C	,	Timer
P	,	Pressure switch
P	E	Earth point
P	1	Pressure transducer
P	2	Pressure transducer
	,	Relay
Q	_	Power relay
Q	_	Relay with 2 contacts
Q	,	Thermal protection relay for
Q	_	compressor Water supply relay
Q	_	Detergent supply relay
\vdash	-	
Q		Detergent pump relay
Q	_	Drain valve relay
Q	8	Heating relay
Q	9	Drain safety relay
Q	s	Main switch
В		Resistance
R	.1	Frames resistance
R	2	Defrosting resistance
R	3	Evaporation resistance
R	4	Heating resistance
R	5	Guard resistance
R	6	Discharge resistance
R	7	Pressure balancing valve resistance
R	8	Frame heating glass doors (on the glass)
R		Perimetrical heater for glass doors
Rı		-
R1	_	Humidify heating element Drying heating element
s	3	Starter
1	ľ	Transformer
Т	1	Automatic transformer
T	2	Ballast
T	X	Transformer for sanitizing
T	В	Thermal breaker
τ	J	Thermometer
v	1	Solenoid-valve
v	2	Water solenoid-valve
V.	3	Solenoid-valve warm gas
V.	4	By-pass valve
v	v	Lamp
W	71	Neon lamp
W	-	UVC lamp
Х	_	Terminal
Х	1	Terminal board
X	М	Evaporator module terminal block
Y	1	Compressor thermal-breaker
Y		Condenser thermal-breaker
Y	3	Evaporator thermal-breaker
_	5	Defrosting termal-breaker
Y	\neg	
Y	6	Fan termal protector

LIMITED WARRANTY

WARRANTY (Warranty valid in USA and Canada) THREE (3) YEAR PARTS AND LABOR WARRANTY:

Beverage-Air Corporation warrants to the original purchaser of Beverage-Air branded equipment, including all parts thereof, that such equipment is free from defects in material and workmanship, under normal use, proper maintenance, and service as indicated by Beverage-Air installation and operation instructions, for a period of three (3) years from the date of installation, or thirty-nine (39) months from the date of shipment from the manufacturer, whichever is earlier.

ADDITIONAL TWO (2) YEAR COMPRESSOR PART WARRANTY*:

In addition to the warranty set forth above, Beverage-Air warrants the hermetically/semi-hermetically sealed compressor (part only) for an additional TWO (2) years beyond the first THREE (3) years warranty period; not to exceed sixty-three (63) months from the date of shipment from Beverage-Air, provided upon receipt of the compressor, manufacturer examination shows the sealed compressor to be defective. This extended warranty does not cover freight for the replacement compressor or freight for the return of the failed compressor.

* Units shipped after 07/01/2024. Previous warranty applies to units shipped prior.

EXCEPTIONS:

- CT96 and CF3 models carry a ONE (1) year parts and labor warranty, limited to fifteen (15) months from date of shipment from Beverage-Air. These are excluded from additional compressor warranty.
- SR/SF (Slate) models carry a TWO (2) year parts and labor warranty, limited to twenty-seven (27) months from date of shipment from Beverage-Air.
- BZ, VM, CDR, DPCR, MT and Blast Chillers carry a THREE (3) year parts and labor warranty; additional TWO (2) years compressor part only.
- Units installed in Residential applications will be not covered under this warranty. Units are intended for Commercial use only.

Also, this compressor-part only warranty does NOT apply to any electrical controls, condenser, evaporator, fan motors, overload switch, starting relay, capacitors, temperature control, filter/drier, accumulator, refrigeration tubing, wiring harness, labor charges, or supplies which are covered by the warranty above.

Note: 3rd party extended warranties are not covered by this warranty statement.

Normal wear parts, as deemed by Beverage-Air, such as but not exclusive to, light bulbs/lamps and gaskets are not covered by this warranty. For the purpose of this warranty, the original purchaser shall be deemed to mean the individual or company for who the product was originally installed.

Units that utilize variable speed compressor technology can experience nuisance tripping on Class A GFCI outlets which have a trip limit of 4 mA to 6 mA. To avoid this issue in a location that requires GFCI circuit protection, Beverage-Air & Victory recommends using a HUBBELL Model Number GFRST83W 20A Heavy Duty Hospital Grade Self-Test GFCI Receptacle. Nuisance tripping not covered under warranty.

Our obligation under this warranty shall be limited to repairing or replacing, including labor, any part of such product, which proves thus defective. Beverage-Air reserves the right to examine any product claimed to be defective and request photos of the unit prior to dispatching service. Moisture or water damage is not covered under warranty. If service is deemed nonwarranty, Beverage-Air reserves the right to bill the end user for service.

The labor warranty shall be for self-contained units only and for standard straight time, which is defined as normal service rate time, for service performed during normal working hours. All warranty labor will be covered at standard time. Any service requested outside of a servicer's normal working hours including weekends and any additional overtime will be at the responsibility of the equipment purchaser. Any part or accessory determined to be defective in the product should be returned to the company within thirty (30) days under the terms of this warranty and must be accompanied by a record of the cabinet model, serial number, and identified with a return material authorization number (RMA#) issued by the manufacturer.

Special installation/applications, including remote locations, are limited in coverage by this warranty. Any installation that requires extra work, and/or travel, to gain access to the unit for service is the sole responsibility of the equipment purchaser.

Improper operation resulting from factors, including but not limited to, improper or negligent cleaning and maintenance, improper installation, low voltage conditions, inadequate wiring, outdoor use (unless otherwise specified) and accidental damage are not manufacturing defects and are strictly the responsibility of the purchaser.

LIMITED WARRANTY (CONT'D)

With the exception of Blast Chillers, the product is designed for maintaining temperature and not bringing food to a desired temperature and therefore cannot be held responsible for this function under warranty. Units must be in a conditioned environment or warranty will be void. Non-standard use of unit can also be subject to reduced or voided warranty.

Condensing coils must be cleaned at regular intervals as a part of preventative maintenance for optimal performance. Failure to do so is subject to a voided warranty. Although cleaning requirements vary in accordance with operation of various products, Beverage-Air recommends a minimum monthly cleaning.

NO CLAIMS CAN BE MADE AGAINST THIS WARRANTY FOR SPOILAGE OF FOOD, PRODUCTS, LOSS OF SALES OR CONSEQUENTIAL DAMAGES.

THE FOREGOING WARRANTIES ARE EXPRESSLY GIVEN IN LIEU OF ALL OTHER WARRANTIES, EXPRESS, IMPLIED, OR STATUTORY, INCLUDING THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, WHICH ARE HEREBY DISCLAIMED, ALL OTHER OBLIGATIONS OR LIABILITIES ON OUR PART, AND WE NEITHER ASSUME, NOR AUTHORIZE ANY OTHER PERSON TO ASSUME FOR US, ANY OBLIGATION OR LIABILITY IN CONNECTION WITH THE SALE OF SAID REFRIGERATION UNITS OR ANY PARTS THERE OF.

This warranty shall not be assignable and shall be honored only in so far as the original purchaser. This warranty does not apply outside the limits of the United States of America and Canada, nor does it apply to any part that has been subject to misuse, neglect, alteration, accident, or to any damage caused by transportation, flood, fire, acts of terrorism, or acts of God.

LIMITATION OF LIABILITY:

Beverage-Air Corporation or their affiliates shall not be liable for any indirect, incidental, special or consequential damages, or losses of a commercial nature arising out of malfunction equipment or its parts components thereof, as a result of defects in material or workmanship.

THE ORIGINAL OWNER'S SOLE AND EXCLUSIVE REMEDY AND BEVERAGE-AIR'S SOLE AND EXCLUSIVE LIABILITY SHALL BE LIMITED TO THE REPAIR OR REPLACEMENT OF PARTS OR COMPONENTS CONTAINED IN THE EQUIPMENT IDENTIFIED ABOVE WHICH UNDER NORMAL USE AND SERVICE MALFUNCTION AS A RESULT OF DEFECTS IN MATERIAL OR WORKMANSHIP, SUBJECT TO THE APPLICABLE PROVISIONS AND LIMITATIONS STATED ABOVE.

Note: Additional Terms and Conditions of sale may apply. Notice: Specifications are subject to change without notice. Contact Beverage-Air for specific model agency approval. All prices are ex-works Brookville, PA. July 1, 2024

Warranty Registration			
Register your product online at Beverage-Air.com/parts-service or fill ou	ıt and mail the form below.		
Cabinet Model Number:	Date Of Installation:		
Cabinet Serial Number:			
Location Of Product			
Business Name:			
Business Street:			
Business City: State: Po	ostal Code:		
Mail to: Beverage-Air, 3779 Champion Blvd, Winston-Salem, NC 27105			

Rev. 11/25



